

RESOLUTION NO. 869

A RESOLUTION declaring an emergency and providing for the repair of an 18-inch sanitary sewer main without submitting the project to competitive bids.

BE IT RESOLVED BY THE COUNCIL OF THE CITY OF CAMAS AS FOLLOWS:

Section I

The Council makes the following findings:

- a. A section of the City's 18-inch sanitary sewer main located between SE Garfield and the north line of the Burlington Northern Railroad is severely cracked and broken.
- b. There is approximate 94 feet of said sanitary sewer main that needs to be replaced.
- c. The existing damage to the sanitary sewer main has impeded the flow of sewage. There is exfiltration of sewage material into the ground and infiltration of storm water into the sanitary sewer line.
- d. The sanitary sewer main in question serves approximately three quarters of the City of Camas.
- e. Repair of the damaged section of the sewer line needs to be undertaken immediately, because any further damage to the line may result in sewage backing up into houses and sewage overflowing into the Washougal River.

Section II

Based upon the foregoing findings, the Council hereby declares the existence of an emergency and directs that the repair of the sanitary sewer main be undertaken immediately without submitting the project for competitive bids.

ADOPTED by the Council at a regular meeting of the Council of the City of Camas this 11th day of January, 1999

SIGNED: _____

Mayor

ATTEST: _____

Clerk

APPROVED as to form:

City Attorney